



中国认可
国际互认
检测
TESTING
CNAS L5772

CE-EMC TEST REPORT

for

Product: Switching DC Power Supply

Model: 305MS

Report No.: PTC25052012601E-EM01

Issued for

DONGGUAN ETOMMENS ELECTRONIC TECHNOLOGY CO., LTD.

**Room 1605, Building 12, No.1 Xuefu Road, Songshan Lake District,
Dongguan City, Guangdong Province, China**

Issued by

Precise Testing & Certification (Guangdong) Co., Ltd.

**Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong,
China.**

TEL: +86-769-3880 8222

FAX: +86-769-3882 6111

Note: This report shall not be reproduced except in full, without the written approval of Precise Testing & Certification (Guangdong) Co., Ltd. This document may be altered or revised by Precise Testing & Certification (Guangdong) Co., Ltd. personnel only, and shall be noted in the revision section of the document. The test results presented in this report only relate to the tested sample.





TABLE OF CONTENTS

1. TEST CERTIFICATION	3
2. TEST SUMMARY	4
3. TEST SITE	5
3.1. TEST FACILITY	5
3.2. MEASUREMENT UNCERTAINTY	5
3.3. DECISION RULE	6
3.4. LIST OF TEST AND MEASUREMENT INSTRUMENTS	6
4. EUT DESCRIPTION	10
5. TEST METHODOLOGY	11
5.1. TEST MODE	11
5.2. EUT SYSTEM OPERATION	11
6. SETUP OF EQUIPMENT UNDER TEST	12
6.1. DESCRIPTION OF SUPPORT UNITS	12
6.2. CONFIGURATION OF SYSTEM UNDER TEST	12
7. EMISSION TEST	13
7.1. CONDUCTED EMISSION MEASUREMENT	13
7.2. RADIATED EMISSION MEASUREMENT	17
7.3. HARMONICS CURRENT MEASUREMENT	21
7.4. VOLTAGE FLUCTUATION AND FLICKS MEASUREMENT	25
8. IMMUNITY TEST	28
8.1. GENERAL DESCRIPTION	28
8.2. GENERAL PERFORMANCE CRITERIA DESCRIPTION	31
8.3. ELECTROSTATIC DISCHARGE (ESD)	32
8.4. RADIATED, RADIO-FREQUENCY, ELECTROMAGNETIC FIELD (RS)	36
8.5. ELECTRICAL FAST TRANSIENT (EFT)	39
8.6. SURGE IMMUNITY TEST	41
8.7. CONDUCTED RADIO FREQUENCY DISTURBANCES (CS)	43
8.8. POWER FREQUENCY MAGNETIC FIELD	45
8.9. VOLTAGE DIP & VOLTAGE INTERRUPTIONS	47
9. PHOTOGRAPHS OF THE TEST CONFIGURATION	50
10. PHOTOGRAPHS OF EUT	54



1. TEST CERTIFICATION


Product:	Switching DC Power Supply
Model:	305MS
Applicant :	DONGGUAN ETOMMENS ELECTRONIC TECHNOLOGY CO., LTD.
Address:	Room 1605, Building 12, No.1 Xuefu Road, Songshan Lake District, Dongguan City, Guangdong Province, China
Manufacturer:	DONGGUAN ETOMMENS ELECTRONIC TECHNOLOGY CO., LTD.
Address:	Room 1605, Building 12, No.1 Xuefu Road, Songshan Lake District, Dongguan City, Guangdong Province, China
Factory:	DONGGUAN ETOMMENS ELECTRONIC TECHNOLOGY CO., LTD.
Address:	Room 1605, Building 12, No.1 Xuefu Road, Songshan Lake District, Dongguan City, Guangdong Province, China
Test Date:	June 10,2025 to June 18,2025
Issued Date:	June 18,2025
Test Voltage:	AC 230V 50Hz
Applicable Standards:	EMC Directive 2014/30/EU EN IEC 61326-1:2021 EN IEC 61000-3-2:2019+A1:2021 EN 61000-3-3:2013+A1:2019+A2:2021

The above equipment has been tested by Precise Testing & Certification (Guangdong) Co., Ltd. and found compliance with the requirements in the technical standards mentioned above. The test results presented in this report only relate to the product/system tested. The Other similar equipment will not necessarily produce the same results due to production tolerance and measurement uncertainties.

Test Engineer.

Technical Manager.


Carson Zhong / Engineer


Simon Pu /Manager

2. TEST SUMMARY

EMISSION			
Standard	Item	Result	Remarks
CISPR 11:2015+A1:2016+A2:2019	Conducted emission (Mains Port)	PASS	Meet Class B limit
	Radiated emission	PASS	Meet Class B limit
EN IEC 61000-3-2:2019+A1:2021	Harmonic current emissions	PASS	Complied with limit
EN 61000-3-3:2013+A1:2019 +A2:2021	Voltage fluctuations & flicker	PASS	Complied with limit

IMMUNITY			
Standard	Item	Result	Remarks
IEC 61000-4-2:2008	ESD	PASS	Complied with the requirements
IEC 61000-4-3:2006+ A1:2007+A2:2010	RS	PASS	Complied with the requirements
IEC 61000-4-4:2012	EFT	PASS	Complied with the requirements
IEC 61000-4-5:2014+A1:2017	Surge	PASS	Complied with the requirements
IEC 61000-4-6:2013	CS	PASS	Complied with the requirements
IEC 61000-4-8:2009	PFMF	N/A	Complied with the requirements
IEC 61000-4-11:2020	Voltage dips & voltage variations	PASS	Complied with the requirements

Note: 1) The test result verdict is decided by the limit of test standard.

2) The information of measurement uncertainty is available upon the customer's request.



3. TEST SITE

3.1. TEST FACILITY

Precise Testing & Certification (Guangdong) Co., Ltd.

Address: Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.

☆ CNAS Registration No.: CNAS L5772

☆ FCC Registration No.: 790290

☆ A2LA Certificate No.: 4408.01

☆ IC Registration No.: 12191A

Test Lab: Guangdong Dongguan Quality Supervision Testing Center

Address: No. 2, Industrial South Road, Songshan Lake Science and Technology Industrial Park, Dongguan City, China

Test items: radio frequency electromagnetic field immunity (R/S) test

3.2. MEASUREMENT UNCERTAINTY

Parameter	U_{lab}	U_{cisp}
Temperature	$\pm 1^{\circ} \text{C}$	-
Humidity	$\pm 5\%$	-
DC and Low Frequency Voltages	$\pm 3\%$	-
Conducted Emission(9KHz-150KHz)	$\pm 3.60\text{dB}$	$\pm 3.80\text{dB}$
Conducted Emission(9KHz-30MHz)	$\pm 3.60\text{dB}$	$\pm 3.40\text{dB}$
Conducted Emission(Control port)	$\pm 3.46\text{dB}$	$\pm 5.00\text{dB}$
Disturbance Power	$\pm 3.68\text{dB}$	$\pm 4.50\text{dB}$
Loop	$\pm 4.02\text{dB}$	$\pm 3.30\text{dB}$
Radiated Emission(30MHz-1GHz)	$\pm 4.76\text{dB}$	$\pm 6.30\text{dB}$
Radiated Emission (1GHz-6GHz)	$\pm 4.44\text{dB}$	$\pm 5.20\text{dB}$
Radiated Emission (6GHz-18GHz)	$\pm 4.44\text{dB}$	$\pm 5.50\text{dB}$

Note 1: This uncertainty represents an expanded uncertainty expressed at approximately the 95% confidence level using a coverage factor of $k=2$.



3.3. DECISION RULE

1. This uncertainty represents an expanded uncertainty expressed at approximately the 95% confidence level using a coverage factor of $k=2$.
2. The Ulab is less than Ucispr, compliance is deemed to occur if no measured disturbance level exceeds the disturbance limit; non-compliance is deemed to occur if any measured disturbance level exceeds the disturbance limit.
3. For conducted emission test of laboratory have a measurement uncertainty greater than that specified in harmonized standard, this equipment can still be used provided that an adjustment is made follows: any additional uncertainty in the test system over and above that specified in harmonized standard should be used to tighten the test requirements-making the test harder to pass. This procedure will ensure that a test system not compliant with harmonized standard does not increase the probability of passing a EUT that would otherwise have failed a test if a test system compliant with harmonized standard had been used.

3.4. LIST OF TEST AND MEASUREMENT INSTRUMENTS

3.4.1. For conducted emission at the mains terminals test

Name of Equipment	Manufacturer	Model	Serial No.	Last Cal.	Calibration Interval
EMI Test Receiver	Rohde&Schwarz	ESCI3	101417	Aug. 15,2024	1 Year
Artificial Mains Network	Rohde&Schwarz	ENV216	101342	Oct. 30,2024	1 Year
ISN	Rohde&Schwarz	ENY81	100118	Aug. 15,2024	1 Year
ISN	Rohde&Schwarz	NTFM8158	00252	Aug. 15,2024	1 Year
Test S/W	Tonscend	JS32-CE/4.0.0.3			

3.4.2. For radiated emission test (30MHz-1GHz)

Name of	Manufacturer	Model	Serial No.	Last Cal.	Calibration
---------	--------------	-------	------------	-----------	-------------



Report No.: PTC25052012601E-EM01

Equipment					Interval
EMI Test Receiver	Rohde&Schwarz	ESPI7	101671	Aug. 15,2024	1 Year
Bilog Antenna	SCHWARZBECK	VULB 9160	9160-3355	Sept. 10,2024	1 Year
Preamplifier (low frequency)	SCHWARZBECK	BBV 9745	9745-0013	Mar. 21, 2025	1 Year
Test S/W	Tonscend	JS32-RE/4.0.0.0			

3.4.3. For radiated emission test (1GHz above)

Name of Equipment	Manufacturer	Model	Serial No.	Last Cal.	Calibration Interval
Spectrum Analyzer	Rohde&Schwarz	FSVR40	6625-01-588-5515	Aug. 15,2024	1 Year
Horn Antenna	SCHWARZBECK	BBHA9120D	9120D-1246	Dec. 12,2024	1 Year
High NOISE AMPLIFIER	ZHINAN	ZN3380C	15002	Aug. 15,2024	1 Year
Test S/W	Tonscend	JS32-RE/4.0.0.0			

3.4.4. For harmonic current emissions and voltage fluctuations/flicker test

Name of Equipment	Manufacturer	Model	Serial No.	Last Cal.	Calibration Interval
Harmonics / Flicker Test System	California Instruments	CTS/PACS-1-115	1534A00401	Aug. 15,2024	1 Year
AC Power Source	California Instruments	3001IX-208-CTS	1534A00401	Aug. 15,2024	1 Year
Test S/W	AMETEK	CTS 4			

3.4.5. For electrostatic discharge immunity test

Name of Equipment	Manufacturer	Model	Serial No.	Last Cal.	Calibration Interval
ESD Generator	SCHLODER	SESD216	606137	Aug. 15,2024	1 Year

**3.4.6. For radio frequency electromagnetic field immunity (R/S) test**

Name of Equipment	Manufacturer	Model	Serial No.	Last Cal.	Calibration Interval
Power meter	Agilent	E4419B	GB42421440	Aug. 15,2024	1 Year
Isotropic Field Probe	Narda	EP-601	611WX80275	Aug. 17,2024	1 Year
Amplifier	SKET	HAP_801000M-250W	201811050	Mar. 21,2025	1 Year
Amplifier	SKET	HAP_0103G-75W	201811051	Aug. 15,2024	1 Year
Amplifier	SKET	HAP_0306G-20W	201811052	Mar. 21,2025	1 Year
Log-periodic Antenna	SKET	ZDSZ-80T1000M-231	SKT231015	Nov. 04,2024	1 Year
Log-periodic Antenna	SKET	ZDSZ-1T6G-232	SKT232079	Nov. 04,2024	1 Year

3.4.7. For electrical fast transient/burst immunity test

Name of Equipment	Manufacturer	Model	Serial No.	Last Cal.	Calibration Interval
EFT Tester	HTEC	HCOMPACT52	190901	Aug. 15,2024	1 Year
EFT Coupling Clamp	HTEC	HEFT 51-C	1416011	Aug. 15,2024	1 Year

3.4.8. For surge immunity test

Name of Equipment	Manufacturer	Model	Serial No.	Last Cal.	Calibration Interval
Surge Tester	HTEC	HCWG 71	174302	Aug. 15,2024	1 Year
Surge Tester	HTEC	TCOMB 4	142103	Aug. 15,2024	1 Year
Surge Tester	HTEC	HTSG 70	175002	Aug. 15,2024	1 Year

3.4.9. For injected currents

Name of Equipment	Manufacturer	Model	Serial No.	Last Cal.	Calibration Interval
-------------------	--------------	-------	------------	-----------	----------------------



Report No.: PTC25052012601E-EM01

C/S Test System	SCHLODER	CDG-6000-25	126A1279/2014	Mar. 21,2025	1 Year
Coupling Decoupling Network	SCHLODER	CDN-M2+3	A2210251/2013	Aug. 15,2024	1 Year
Coupling/decoupling network	SCHLODER	CMCL-20	180901961-020 1	Aug. 15,2024	1 Year
Test S/W	SCHLODER	CDG/1.0.0.0			

3.4.10. For power frequency magnetic field immunity test

Name of Equipment	Manufacturer	Model	Serial No.	Last Cal.	Calibration Interval
Magnetic Field Tester	HTEC	HMFG-100	HMFG-100	Aug. 15,2024	1 Year

3.4.11. For voltage dips and short interruptions immunity test

Name of Equipment	Manufacturer	Model	Serial No.	Last Cal.	Calibration Interval
Dips Tester	HTEC	HV1P16T	170901	Aug. 15,2024	1 Year



4. EUT DESCRIPTION

Product	Switching DC Power Supply
Model	305MS
Supplied Voltage	Input: 115-230V $\pm$ 10% , 50Hz/60Hz Output: 0~30V, 0~5A
Power	150W Max.

I/O PORT

I/O PORT TYPES	Q'TY	TESTED WITH
AC Port	1	☒
DC Port	1	☐

Models Difference

/

5. TEST METHODOLOGY

5.1. TEST MODE

The EUT was tested together with the thereafter additional components, and a configuration, which produced the worst emission levels, was selected and recorded in this report.

The following test mode(s) were assessed.

Test Items		Test Mode
Emission	Conducted Emission	Full load
	Radiated Emission	Full load
	Harmonic current emissions	Full load
	Voltage fluctuations & flicker	Full load
Immunity	ESD	Full load
	RS	Full load
	EFT	Full load
	Surge	Full load
	C/S	Full load
	PFMF	N/A
	Dips	Full load

5.2. EUT SYSTEM OPERATION

1. Set up EUT with the support equipment.
2. Make sure the EUT work normally during the test.

6. SETUP OF EQUIPMENT UNDER TEST

6.1. DESCRIPTION OF SUPPORT UNITS


The EUT has been tested as an independent unit together with other necessary accessories or support units. The following support units or accessories were used to form a representative test configuration during the tests.

No.	Equipment	Model	Serial No.	FCC ID	Trade Name	Data Cable	Power Cord
1.	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Note: 1) All the equipment/cables were placed in the worst-case configuration to maximize the emission during the test.

2) Grounding was established in accordance with the manufacturer's requirements and conditions for the intended use.

6.2. CONFIGURATION OF SYSTEM UNDER TEST



(EUT: Switching DC Power Supply)

7. EMISSION TEST

7.1. CONDUCTED EMISSION MEASUREMENT

7.1.1. LIMITS

FREQUENCY (MHz)	Class A		Class B	
	Quasi-peak dB(μ V)	Average dB(μ V)	Quasi-peak dB(μ V)	Average dB(μ V)
0.15 - 0.5	79	66	66-56	56-46
0.5 - 5.0	73	60	56	46
5.0 - 30.0	73	60	60	50

Note: 1) The lower limit shall apply at the transition frequencies.

2) The limit decreases in line with the logarithm of the frequency in the range of 0.15 to 0.50 MHz.

7.1.2. TEST PROCEDURES

The EUT and Support equipment, if needed, was set up as per the test configuration to simulate typical usage per the user's manual. When the EUT is a tabletop system, a wooden table with a height of 0.8 meters is used and is placed on the ground plane. When the EUT is floor standing equipment, it is placed on the ground plane, which has a 3-12 mm non-conductive covering to insulate the EUT from the ground plane. The EUT should be 0.8 m apart from the AMN, where the mains cable supplied by the manufacturer is longer than 1 m, the excess should be folded at the centre into a bundle no longer than 0.4 m, Details please refer to test setup photography.


The Receiver scanned from 150 kHz to 30 MHz for emissions in each of the test modes. During the above scans, the emissions were maximized by cable manipulation.

A scan was taken on both of the power lines, Line and neutral, recording at least the six highest emissions. Emission frequency and amplitude were recorded into a computer in which correction factors were used to calculate the emission level and compare reading to the applicable limit. The test data of the worst-case condition(s) was recorded.

The test data of the worst-case condition(s) was recorded.

Note: Test Software Name: Tonscend,JS32-RE/4.0.0.3.

7.1.3. TEST SETUP



For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

7.1.4. TEST RESULT

Product name	Switching DC Power Supply	Tested By	LI
Model	305MS	Detector Function	Peak / Quasi-peak/AV
Test Mode	Full load	6 dB Bandwidth	9 kHz
Environmental Conditions	25.5°C, 54 % RH, 101.5 kPa	Test Result	Pass

Note:

L = Line Line, N = Neutral Line

Freq. = Emission frequency in MHz

Reading level (dBμV) = Receiver reading

Corr. Factor (dB) = attenuator + Cable loss

Level (dBμV) = Reading level (dBμV) + Corr. Factor (dB)

Limit (dBμV) = Limit stated in standard


Over Limit (dB) = Level (dBμV) – Limit (dBμV)

QP = Quasi-Peak

AV = Average

Please refer to the following diagram:

Line:




Final Data List

NO.	Freq. [MHz]	QP Reading [dBμV]	Factor [dB]	QP Value [dBμV]	QP Limit [dBμV]	QP Margin [dB]	AV Reading [dBμV]	AV Value [dBμV]	AV Limit [dBμV]	AV Margin [dB]	Verdict
1	0.209	54.47	9.81	64.28	79.00	14.72	40.55	50.36	66.00	15.64	PASS
2	0.339	40.03	9.81	49.84	79.00	29.16	23.77	33.58	66.00	32.42	PASS
3	0.384	38.20	9.81	48.01	79.00	30.99	18.94	28.75	66.00	37.25	PASS
4	0.416	36.87	9.81	46.68	79.00	32.32	23.12	32.93	66.00	33.07	PASS
5	0.492	31.40	9.81	41.21	79.00	37.79	11.43	21.24	66.00	44.76	PASS
6	0.605	29.59	9.81	39.40	73.00	33.60	15.53	25.34	60.00	34.66	PASS



Neutral:



Final Data List

NO.	Freq. [MHz]	QP Reading [dBμV]	Factor [dB]	QP Value [dBμV]	QP Limit [dBμV]	QP Margin [dB]	AV Reading [dBμV]	AV Value [dBμV]	AV Limit [dBμV]	AV Margin [dB]	Verdict
1	0.195	54.23	9.81	64.04	79.00	14.96	40.27	50.08	66.00	15.92	PASS
2	0.213	49.92	9.81	59.73	79.00	19.27	29.55	39.36	66.00	26.64	PASS
3	0.335	40.28	9.81	50.09	79.00	28.91	27.52	37.33	66.00	28.67	PASS
4	0.380	39.04	9.81	48.85	79.00	30.15	22.57	32.38	66.00	33.62	PASS
5	0.420	38.07	9.81	47.88	79.00	31.12	21.68	31.49	66.00	34.51	PASS
6	0.663	30.06	9.82	39.88	73.00	33.12	15.80	25.62	60.00	34.38	PASS

7.2. RADIATED EMISSION MEASUREMENT

7.2.1. LIMITS

FREQUENCY (MHz)	Class A(At 3m)	Class B(At 3m)
	Quasi-peak dB(μ V/m)	Quasi-peak dB(μ V/m)
30 ~ 230	50	40
230 ~ 1000	57	47

Note: 1) The lower limit shall apply at the transition frequencies.

2) Emission level (dB μ V/m) = 20 log Emission level (μ V/m).

7.2.2. TEST PROCEDURE

The equipment was set up as per the test configuration to simulate typical usage per the user's manual. When the EUT is a tabletop system, a wooden turntable with a height of 0.8 meters is used which is placed on the ground plane. When the EUT is floor standing equipment, it is placed on the ground plane which has a 0.1 m non-conductive covering to insulate the EUT from the ground plane.

The antenna was placed at 3 meter away from the EUT. The antenna connected to the spectrum analyzer via a cable and at times a pre-amplifier would be used.


The analyzer / receiver quickly scanned from 30 MHz to 1000 MHz. The EUT test program was started. Emissions were scanned and measured rotating the EUT to 360 degrees and positioning the antenna 1 to 4 meters above the ground plane, in both the vertical and the horizontal polarization, to maximize the emission reading level.

During the above scans, the emissions were maximized by cable manipulation. Each modes is measured, recorded at least the six highest emissions. The emission frequency, amplitude, antenna position, polarization and turntable position were recorded into a computer in which correction factors were used to calculate the emission level and compare reading to the applicable limit and only Q.P. reading is presented.

The test data of the worst-case condition(s) was recorded.

Note: Test Software Name: Tonscend,JS32-RE/4.0.0.0..

7.2.3. TEST SETUP



For the actual test configuration, please refer to the related item – Photographs of the Test Configuration

7.2.4. TEST RESULT

Product name	Switching DC Power Supply	Antenna Distance	3 m
Model	305MS	Antenna Pole	Vertical / Horizontal
Test Mode	Full load	Detector Function	Peak / Quasi-peak
Environmental Conditions	25.5°C, 54 % RH, 101.5 kPa	6 dB Bandwidth	120 kHz
Tested by	LIN	Test Result	Pass

Note:

Freq. = Emission frequency in MHz

Reading level (dBμV) = Receiver reading(dBμV)

Corr.Factor (dB/m)=Antenna factor(dB/m)+Cable loss(dB)-Preamp Factor(dB)

Measurement (dBμV/m)=Reading level(dBμV)+ Corr. Factor (dB/m)

Limit (dBμV/m) = Limit stated in standard


Over Limit (dB) = Measurement (dBμV/m) – Limit (dBμV/m)

QP = Quasi-Peak

The highest frequency of the internal sources of the EUT was less than 108 MHz, so the measurement was only made up to 1 GHz.


Please refer to the following diagram:

Vertical:



Final Data List[QP]								
NO.	Freq. [MHz]	QP Reading [dBμV]	Factor [dB/m]	QP Value [dBμV/m]	QP Limit [dBμV/m]	QP Margin [dB]	Polarity	Verdict
1	54.01	55.46	-10.02	45.44	50.00	4.56	Vertical	PASS
2	60.31	53.84	-10.37	43.47	50.00	6.53	Vertical	PASS
3	94.75	57.72	-14.96	42.76	50.00	7.24	Vertical	PASS
4	135.49	56.51	-10.70	45.81	50.00	4.19	Vertical	PASS
5	184.72	55.8	-11.76	44.04	50.00	5.96	Vertical	PASS
6	193.45	56.15	-12.33	43.82	50.00	6.18	Vertical	PASS

Horizontal:



Final Data List[QP]								
NO.	Freq. [MHz]	QP Reading [dBμV]	Factor [dB/m]	QP Value [dBμV/m]	QP Limit [dBμV/m]	QP Margin [dB]	Polarity	Verdict
1	57.65	54.79	-10.17	44.62	50.00	5.38	Horizontal	PASS
2	60.07	54.51	-10.35	44.16	50.00	5.84	Horizontal	PASS
3	132.09	52.33	-11.05	41.28	50.00	8.72	Horizontal	PASS
4	142.04	53.43	-9.87	43.56	50.00	6.44	Horizontal	PASS
5	179.38	56.19	-11.16	45.03	50.00	4.97	Horizontal	PASS
6	199.99	57.79	-12.76	45.03	50.00	4.97	Horizontal	PASS

7.3. HARMONICS CURRENT MEASUREMENT

7.3.1. LIMITS OF HARMONICS CURRENT MEASUREMENT

Limit for Class A equipment	
Harmonics Order N	Max. permissible harmonics current A
Odd harmonics	
3	2.30
5	1.14
7	0.77
9	0.40
11	0.33
13	0.21
$15 \leq n \leq 39$	$0.15 \times (15/n)$
Even harmonics	
2	1.08
4	0.43
6	0.30
$8 \leq n \leq 40$	$0.23 \times 8/n$

Limit for Class D equipment		
Harmonics Order n	Max. permissible harmonics current per watt mA/W	Max. permissible harmonics current A
Odd Harmonics only		
3	3.4	2.30
5	1.9	1.14
7	1.0	0.77
9	0.5	0.40
11	0.35	0.33
13	0.30	0.21
$15 \leq n \leq 39$ (odd harmonics only)	3.85/n	$0.15 \times (15/n)$

Limit for Class C equipment ^a	
Harmonics Order n	Max. permissible harmonics current expressed as a percentage of the input current at the fundamental frequency A
2	2
3	27 ^b
5	10
7	7
9	5
$11 \leq n < \leq 39$ (odd harmonics only)	3

^a:For some Class C products, other emission limits apply (see BS EN IEC 61000-3-2 7.4).

^b:The limit is determined based on the assumption of modern lighting technologies having power factors of 0,90 or higher

Note: Class A, B, C and D are classified according to item 7.3.2.of this report

7.3.2. TEST PROCEDURES

The EUT was placed on the top of a wooden table 0.8 meters above the ground and operated to produce the maximum harmonic. The classification of EUT is according to section 5 of EN IEC 61000-3-2.

The EUT is classified as follows:

Class A:

Equipment not specified as belonging to Class B, C or D shall be considered as Class A equipment.

Some examples of Class A equipment are:

- balanced three-phase equipment;
- household appliances, excluding those specified as belonging to Class B, C or D;
- vacuum cleaners;
- high pressure cleaners;
- tools, excluding portable tools;
- independent phase control dimmers;
- audio equipment;
- professional luminaires for stage lighting and studios.

NOTE 1 Equipment that can be shown to have a significant effect on the supply system might be reclassified in a future edition of this document, taking into account the following factors:

- number of pieces of equipment in use;
- duration of use;
- simultaneity of use;
- power consumption;
- harmonic spectrum, including phase.

Class B:

- portable tools;
- arc welding equipment which is not professional equipment.

Class C:

- lighting equipment.

Class D:

Equipment having a specified power less than or equal to 600 W according to 6.3.2, of the following types:


- personal computers and personal computer monitors;

- television receivers;
- refrigerators and freezers having one or more variable-speed drives to control compressor motor(s).

NOTE 2 Class D limits are reserved for equipment that, by virtue of the factors listed in note 1 , can be shown to have a pronounced effect on the public electricity supply system.

The correspondent test program of test instrument to measure the current harmonics emanated from EUT is chosen. The measure time shall be not less than the time necessary for the EUT to be exercised.

7.3.3. TEST SETUP



For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

7.3.4. TEST RESULT

Product	Switching DC Power Supply	Tested by	Bruce
Model	305MS	Limits	Class ☒ A ☐ B ☐ C ☐ D
Test Mode	Full load	Observation Period (Tp)	2.5 mins
Environmental Conditions	25.5°C, 54 % RH, 101.5 kPa	Test Results	Pass

Note: 1) Limits classified according to item 7.3.2 of this report.

Since the power of product is less than 75W, according to the standard BS EN IEC 61000-3-2, this item isn't applicable to the products.



Please refer to the following test data:

Test Result: Pass

Source qualification: Normal

THC(A): 0.332

I-THD(%): 164.1

POHC(A): 0.044

POHC Limit(A): 0.251

Highest parameter values during test:

V_RMS (Volts): 230.03

Frequency(Hz): 50.00

I_Peak (Amps): 3.289

I_RMS (Amps): 0.931

I_Fund (Amps): 0.298

Crest Factor: 11.549

Power (Watts): 150.9

Power Factor: 0.976

Harm#	Harms(avg)	100%Limit	%of Limit	Harms(max)	150%Limit	%of Limit	Status
2	0.005	1.080	0.5	0.010	1.620	0.6	Pass
3	0.184	2.300	8.0	0.276	3.450	8.0	Pass
4	0.005	0.430	1.2	0.010	0.645	1.5	Pass
5	0.166	1.140	14.6	0.248	1.710	14.5	Pass
6	0.005	0.300	N/A	0.009	0.450	N/A	Pass
7	0.143	0.770	18.5	0.210	1.155	18.2	Pass
8	0.004	0.230	N/A	0.008	0.345	N/A	Pass
9	0.115	0.400	28.8	0.168	0.600	27.9	Pass
10	0.004	0.184	N/A	0.007	0.276	N/A	Pass
11	0.087	0.330	26.3	0.126	0.495	25.4	Pass
12	0.003	0.153	N/A	0.006	0.230	N/A	Pass
13	0.060	0.210	28.6	0.086	0.315	27.3	Pass
14	0.003	0.131	N/A	0.005	0.197	N/A	Pass
15	0.037	0.150	24.9	0.052	0.225	23.2	Pass
16	0.002	0.115	N/A	0.005	0.173	N/A	Pass
17	0.022	0.132	16.7	0.034	0.198	17.0	Pass
18	0.002	0.102	N/A	0.004	0.153	N/A	Pass
19	0.020	0.118	16.9	0.028	0.178	15.9	Pass
20	0.002	0.092	N/A	0.004	0.138	N/A	Pass
21	0.023	0.107	21.2	0.028	0.161	17.7	Pass
22	0.002	0.084	N/A	0.004	0.125	N/A	Pass
23	0.023	0.098	23.1	0.028	0.147	19.3	Pass
24	0.001	0.077	N/A	0.003	0.115	N/A	Pass
25	0.020	0.090	21.8	0.026	0.135	19.4	Pass
26	0.001	0.071	N/A	0.003	0.107	N/A	Pass
27	0.015	0.083	17.9	0.021	0.125	16.9	Pass
28	0.001	0.066	N/A	0.003	0.099	N/A	Pass
29	0.010	0.078	13.1	0.015	0.116	12.5	Pass
30	0.001	0.061	N/A	0.003	0.092	N/A	Pass
31	0.007	0.073	9.9	0.009	0.109	8.3	Pass
32	0.001	0.058	N/A	0.002	0.086	N/A	Pass
33	0.007	0.068	10.0	0.010	0.102	9.6	Pass
34	0.001	0.054	N/A	0.002	0.081	N/A	Pass
35	0.007	0.064	11.3	0.010	0.096	10.6	Pass
36	0.001	0.051	N/A	0.002	0.077	N/A	Pass
37	0.007	0.061	11.6	0.010	0.091	10.8	Pass
38	0.001	0.048	N/A	0.002	0.073	N/A	Pass
39	0.006	0.058	10.5	0.009	0.087	10.1	Pass
40	0.001	0.046	N/A	0.002	0.069	N/A	Pass

7.4. VOLTAGE FLUCTUATION AND FLICKS MEASUREMENT


7.4.1. LIMITS OF VOLTAGE FLUCTUATION AND FLICKS MEASUREMENT

TEST ITEM	LIMIT	REMARK
P_{st}	1.0	P_{st} means short-term flicker indicator.
P_{lt}	0.65	P_{lt} means long-term flicker indicator.
T_{dt} (ms)	500	T_{dt} means maximum time that dt exceeds 3 %.
d_{max} (%)	4/6/7 %	d_{max} means maximum relative voltage change.
dc (%)	3.3 %	dc means relative steady-state voltage change

7.4.2. TEST PROCEDURE

The EUT was placed on the top of a wooden table 0.8 meters above the ground and operated to produce the most unfavorable sequence of voltage changes under full load operating conditions. During the flick measurement, the measure time shall include that part of whole operation cycle in which the EUT produce the most unfavorable sequence of voltage changes. The observation period for short-term flicker indicator is 10 minutes and the observation period for long-term flicker indicator is 2 hours.

7.4.3. TEST SETUP



For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.



Report No.: PTC25052012601E-EM01

7.4.4. TEST RESULT

Product	Switching DC Power Supply	Tested by	Bruce
Model	305MS	Observation Period (Tp)	10 mins
Test Mode	Full load	Test Result	Pass
Environmental Conditions	25.5°C, 54 % RH, 101.5 kPa		



Report No.: PTC25052012601E-EM01


Please refer to the following test data:

Test Result: Pass

Status: Test completed

Pst and limit line

European Limits



Plt and limit line



Parameter values recorded during the test:

Vrms at the end of test (Volt): 230.12

T-max (mS): 0

Highest dc (%): 0.00

Highest dmax (%): 0.00

Highest Pst (10 min. period): 0.233

Highest Plt (2 hr. period): 0.102

Test limit (mS): 500.0 Pass

Test limit (%): 3.30 Pass

Test limit (%): 4.00 Pass

Test limit: 1.000 Pass

Test limit: 0.650 Pass

8. IMMUNITY TEST

8.1. GENERAL DESCRIPTION

Table1 – Immunity test requirements for equipment intended to be used in a BASIC ELECTROMAGNETIC ENVIRONMENT

PORT	Phenomenon	Basic standard	Test value	Performance criterion
ENCLOSURE	ESD	IEC 61000-4-2	±4 kV contact discharge ±8 kV air discharge	B B
	Electromagnetic field	IEC 61000-4-3	3 V/m (80 MHz to 1 GHz; 1,4 GHz to 6 GHz) ^a	A
	Power frequency magnetic field ^b	IEC 61000-4-8	3 A/m (50 Hz, 60 Hz)	A
AC power (including protective earth)	Burst	IEC 61000-4-4	±1 kV (5 kHz or 100 kHz)	B
	Surge	IEC 61000-4-5	±0,5 kV line-to-line ±1 kV line-to-ground	B B
	Conducted RF	IEC 61000-4-6	3 V (150 kHz to 80 MHz)	A
	Voltage dip	IEC 61000-4-11	0 % during half cycle 0 % during 1 cycle 70 % during 25/30 cycles ^c	B B C
	Short interruptions	IEC 61000-4-11	0 % during 250/300 cycles ^c	C
DC power ^{d, e} (including protective earth)	Burst	IEC 61000-4-4	±1 kV (5 kHz or 100 kHz)	B
	Surge	IEC 61000-4-5	±0,5 kV line-to-line ±1 kV line-to-ground	B B
	Conducted RF	IEC 61000-4-6	3 V (150 kHz to 80 MHz)	A
I/O signal/control ^e (including functional earth)	Burst ^d	IEC 61000-4-4	±0,5 kV (5 kHz or 100 kHz)	B
	Surge ^f	IEC 61000-4-5	±1 kV line-to-ground	B
	Conducted RF ^d	IEC 61000-4-6	3 V (150 kHz to 80 MHz)	A
I/O signal/control ^e connected directly to mains supply	Burst ^d	IEC 61000-4-4	±1 kV (5 kHz or 100 kHz)	B
	Surge ^f	IEC 61000-4-5	±0,5 kV line-to-line ±1 kV line-to-ground	B B
	Conducted RF ^d	IEC 61000-4-6	3 V (150 kHz to 80 MHz)	A

^a In case testing is performed also in the frequency range from 1 GHz to 1,4 GHz, the same test level is recommended.

^b Only to magnetically sensitive equipment.

^c For example, "25/30 cycles" means "25 cycles for 50 Hz test" or "30 cycles for 60 Hz test".

^d Only in the case of lines >3 m.

^e DC POWER PORTS intended to be connected to a low voltage DC supply (≤ 60 V), where secondary circuits (isolated from the AC mains supply) are not subject to transient overvoltages (i.e. reliably-grounded, capacitively-filtered DC secondary circuits) shall be regarded as I/O signal/control PORTS.

^f Only in the case of LONG-DISTANCE LINES.

Table 2 – Immunity test requirements for equipment intended to be used in an INDUSTRIAL ELECTROMAGNETIC ENVIRONMENT

PORT	Phenomenon	Basic standard	Test value	Performance criterion
ENCLOSURE	ESD	IEC 61000-4-2	±4 kV contact discharge ±8 kV air discharge	B B
	Electromagnetic field	IEC 61000-4-3	10 V/m (80 MHz to 1 GHz) 3 V/m (1,4 GHz to 6 GHz) ^a	A A
	Power frequency magnetic field ^b	IEC 61000-4-8	30 A/m (50 Hz, 60 Hz)	A
AC power (including protective earth)	Burst	IEC 61000-4-4	±2 kV (5 kHz or 100 kHz)	B
	Surge	IEC 61000-4-5	±1 kV line-to-line ±2 kV line-to-ground	B B
	Conducted RF	IEC 61000-4-6	3 V (150 kHz to 80 MHz), see NOTE	A
	Voltage dip	IEC 61000-4-11	0 % during 1 cycle 40 % during 10/12 cycles ^c 70 % during 25/30 cycles ^c	B C C
	Short interruptions	IEC 61000-4-11	0 % during 250/300 cycles ^c	C
DC power ^{d, e} (including protective earth)	Burst	IEC 61000-4-4	±2 kV (5 kHz or 100 kHz)	B
	Surge	IEC 61000-4-5	±1 kV line-to-line ±2 kV line-to-ground	B B
	Conducted RF	IEC 61000-4-6	3 V (150 kHz to 80 MHz) see NOTE	A
I/O signal/control ^e (including functional earth)	Burst ^d	IEC 61000-4-4	±1 kV (5 kHz or 100 kHz)	B
	Surge ^f	IEC 61000-4-5	±1 kV line-to-ground	B
	Conducted RF ^d	IEC 61000-4-6	3 V (150 kHz to 80 MHz) see NOTE	A
I/O signal/control ^e (connected directly to mains supply)	Burst ^d	IEC 61000-4-4	±2 kV (5 kHz or 100 kHz)	B
	Surge ^f	IEC 61000-4-5	±1 kV line-to-line ±2 kV line-to-ground	B B
	Conducted RF ^d	IEC 61000-4-6	3 V (150 kHz to 80 MHz) see NOTE	A

NOTE Equipment considered in this table is typically used in industrial installations with the cabling arranged on metallic structures. This reduces coupling of electromagnetic fields into cables and hence justifies a lower immunity level compared to that given in the generic immunity standard IEC 61000-6-2. The level of 3 V is used for more than 15 years without immunity issues and hence proved to be sufficient.

^a In case testing is performed also in the frequency range from 1 GHz to 1,4 GHz, the same test level as above 1,4 GHz is recommended.

^b Only to magnetically sensitive equipment.

^c For example, "25/30 cycles" means "25 cycles for 50 Hz test" or "30 cycles for 60 Hz test".

^d Only in the case of lines > 3 m.

^e DC power PORTS intended to be connected to a low voltage DC supply (≤ 60 V), where secondary circuits (isolated from the AC mains supply) are not subject to transient overvoltages (i.e. reliably-grounded, capacitively-filtered DC secondary circuits) shall be regarded as I/O signal/control PORTS.

^f Only in the case of LONG-DISTANCE LINES.

Table 3 – Immunity test requirements for equipment intended to be used in a CONTROLLED ELECTROMAGNETIC ENVIRONMENT

PORT	Phenomenon	Basic standard	Test value	Performance criterion
ENCLOSURE	ESD	IEC 61000-4-2	±4 kV contact discharge ±8 kV air discharge	B B
	Electromagnetic field	IEC 61000-4-3	1 V/m (80 MHz to 1 GHz; 1,4 GHz to 6 GHz) ^a	A
AC power (including protective earth)	Burst	IEC 61000-4-4	±1 kV (5 kHz or 100 kHz)	B
	Surge	IEC 61000-4-5	±0,5 kV line-to-line ±1 kV line-to-ground	B B
	Conducted RF	IEC 61000-4-6	1 V (150 kHz to 80 MHz)	A
DC power ^{b, c} (including protective earth)	Burst	IEC 61000-4-4	±1 kV (5 kHz or 100 kHz)	B
	Conducted RF	IEC 61000-4-6	1 V (150 kHz to 80 MHz)	A
I/O signal/control ^c (including functional earth)	Burst ^b	IEC 61000-4-4	±0,5 kV (5 kHz or 100 kHz)	B
	Conducted RF ^b	IEC 61000-4-6	1 V (150 kHz to 80 MHz)	A

^a In case testing is performed also in the frequency range from 1 GHz to 1,4 GHz, the same test level is recommended.

^b Only in the case of lines > 3 m.

^c DC power PORTS intended to be connected to a low voltage DC supply (≤ 60 V), where secondary circuits (isolated from the AC mains supply) are not subject to transient overvoltages (i.e. reliably-grounded, capacitively-filtered DC secondary circuits) shall be regarded as I/O signal/control PORTS.



8.2. GENERAL PERFORMANCE CRITERIA DESCRIPTION

Criteria A:	During and after the test the EUT shall continue to operate as intended without operator intervention. No degradation of performance or loss of function is allowed below a minimum performance level specified by the manufacturer when the EUT is used as intended. The performance level may be replaced by a permissible loss of performance. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the EUT if used as intended.
Criteria B:	After the test, the EUT shall continue to operate as intended without operator intervention. No degradation of performance or loss of function is allowed, after the application of the phenomena below a performance level specified by the manufacturer, when the EUT is used as intended. The performance level may be replaced by a permissible loss of performance. During the test, degradation of performance is allowed. However, no change of operating state or stored data is allowed to persist after the test. If the minimum performance level (or the permissible performance loss) is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the EUT if used as intended.
Criteria C:	During and after testing, a temporary loss of function is allowed, provided the function is self-recoverable, or can be restored by the operation of the controls or cycling of the power to the EUT by the user in accordance with the manufacturer's instructions. Functions, and/or information stored in non-volatile memory, or protected by a battery backup, shall not be lost.

8.3. ELECTROSTATIC DISCHARGE (ESD)

8.3.1. TEST SPECIFICATION

Basic Standard:	IEC 61000-4-2
Discharge Impedance:	330 Ω
Charging Capacity:	150 pF
Discharge Voltage:	Air Discharge: ± 8 kV (Direct) Contact Discharge: ± 4 kV (Direct/Indirect)
Polarity:	Positive & Negative
Number of Discharge:	10
Discharge Mode:	1 time/s
Performance Criterion:	B

8.3.2. TEST PROCEDURE

The discharges shall be applied in two ways:


- Contact discharges to the conductive surfaces and coupling planes:
50 dischargers (10 times positive and 10 times negative polarity) shall be applied on each accessible metallic part of the enclosure, terminals are excluded. In case of a non-conductive enclosure, dischargers shall be applied on the horizontal or vertical coupling planes. Test shall be performed at a maximum repetition rate of one discharge per second.
- Air discharges at slots and apertures and insulating surfaces:
On those parts of the EUT where it is not possible to perform contact discharge testing, the equipment should be investigated to identify user accessible points where breakdown may occur. Such points are tested using the air discharge method. This investigation should be restricted to those area normally handled by the user. A minimum of 10 single air discharges shall be applied to the selected test point for each such area.

The basic test procedure was in accordance with IEC 61000-4-2:

- The EUT was located 0.1 m minimum from all side of the HCP (dimensions 1.6 m x 0.8 m).
- The support units were located another table 30 cm away from the EUT, but direct support unit was/were located at same location as EUT on the HCP and keep at a distance of 10cm with EUT.
- The time interval between two successive single discharges was at least 1 second.

- d) Contact discharges were applied to the non-insulating coating, with the pointed tip of the generator penetrating the coating and contacting the conducting substrate.
- e) Air discharges were applied with the round discharge tip of the discharge electrode approaching the EUT as fast as possible (without causing mechanical damage) to touch the EUT. After each discharge, the ESD generator was removed from the EUT and re-triggered for a new single discharge. The test was repeated until all discharges were complete.
- f) At least ten single discharges (in the most sensitive polarity) were applied at the front edge of each HCP opposite the center point of each unit of the EUT and 0.1 meter from the front of the EUT. The long axis of the discharge electrode was in the plane of the HCP and perpendicular to its front edge during the discharge.
- g) At least ten single discharges (in the most sensitive polarity) were applied to the center of one vertical edge of the Vertical Coupling Plane (VCP) in sufficiently different positions that the four faces of the EUT were completely illuminated. The VCP (dimensions 0.5 m x 0.5 m) was placed vertically to and 0.1 meter from the EUT.

8.3.3. TEST SETUP



For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

Note:

1) TABLE-TOP EQUIPMENT

The configuration consisted of a wooden table 0.8 meters high standing on the ground reference plane (GRP). The GRP consisted of a sheet of aluminum at least 0.25 mm thick, and 2.5 meters square connected to the protective grounding system. A horizontal coupling plane (HCP) (1.6 m x 0.8 m) was placed on the table and attached to the GRP by means of a cable with 940k total impedance. The equipment under test, was installed in a representative system as described in section 7 of IEC 61000-4-2, and its cables were placed on the HCP and isolated by an insulating support of 0.5 mm thickness. A distance of 1-meter minimum was provided between the EUT and the walls of the laboratory and any other metallic structure.

2) FLOOR-STANDING EQUIPMENT

The equipment under test was installed in a representative system as described in section 7 of IEC 61000-4-2, and its cables were isolated from the ground reference plane by an insulating support of 0.1 meter thickness. The GRP consisted of a sheet of aluminum that is at least 0.25 mm thick, and 2.5 meters square connected to the protective grounding system and extended at least 0.5 meters from the EUT on all sides.



8.3.4. TEST RESULT

Product	Switching DC Power Supply	Environmental Conditions	25.5°C, 54 % RH, 101.5 kPa
Model	305MS	Tested By	Bruce
Test mode	Full load	Test Result	Pass

Air Discharge					
Test Points	Test Levels	Results			
	± 8 kV	Pass	Fail	Observation	Performance Criterion
Button	☒	☒	☐	Note ☒ A ☐ B ☐ C	B

Contact Discharge					
Test Points	Test Levels	Results			
	± 4 kV	Pass	Fail	Observation	Performance Criterion
Screw	☒	☒	☐	Note ☒ A ☐ B ☐ C	B
Metal	☒	☒	☐	Note ☒ A ☐ B ☐ C	B
HCP	☒	☒	☐	Note ☒ A ☐ B ☐ C	B
VCP	☒	☒	☐	Note ☒ A ☐ B ☐ C	B

Note: A) There was no change compared with initial operation during the test.

B) During the test, degradation of performance is allowed. However, no change of operating state or stored data is allowed to persist after the test. If the minimum performance level (or the permissible performance loss) is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the EUT if used as intended.

C) During and after testing, a temporary loss of function is allowed, provided the function is self-recoverable, or can be restored by the operation of the controls or cycling of the power to the EUT by the user in accordance with the manufacturer's instructions.

8.4. RADIATED, RADIO-FREQUENCY, ELECTROMAGNETIC FIELD (RS)

8.4.1. TEST SPECIFICATION


Basic Standard:	IEC 61000-4-3
Frequency Range:	80MHz to 6GHz
Field Strength:	3V/m
Modulation:	1 kHz Sine Wave, 80 %, AM Modulation
Frequency Step:	1 % of preceding frequency value
Polarity of Antenna:	Horizontal and Vertical
Test Distance:	3 m
Antenna Height:	1.5 m
Performance Criterion:	A

8.4.2. TEST PROCEDURE

The test procedure was in accordance with IEC 61000-4-3

- The testing was performed in a fully anechoic chamber. The transmit antenna was located at a distance of 3 meters from the EUT.
- The frequency range is swept from 80MHz to 1GHz, 1.4GHz to 2GHz, 2.0GHz to 2.7GHz, with the signal 80% amplitude modulated with a 1 kHz sine-wave. The rate of sweep did not exceed 1.5×10^{-3} decade/s, where the frequency range is swept incrementally, the step size was 1 % of preceding frequency value.
- The dwell time at each frequency shall be not less than the time necessary for the EUT to be able to respond.
- The test was performed with the EUT exposed to both vertically and horizontally polarized fields on each of the four sides.

8.4.3. TEST SETUP



For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

Note:

TABLETOP EQUIPMENT

The EUT installed in a representative system as described in section 7 of IEC 61000-4-3 was placed on a non-conductive table 0.8 meters in height. The system under test was connected to the power and signal wire according to relevant installation instructions.

FLOOR STANDING EQUIPMENT

The EUT installed in a representative system as described in section 7 of IEC 61000-4-3 was placed on a non-conductive wood support 0.1 meters in height. The system under test was connected to the power and signal wire according to relevant installation instructions.



8.4.4. TEST RESULT

Product	Switching DC Power Supply	Environmental Conditions	25.5°C, 54 % RH, 101.5 kPa
Model	305MS	Tested By	Bruce
Test mode	Full load	Test Result	Pass

Frequency (MHz)	Polarity	Position	Field Strength (V/m)	Observation	Performance Criterion
80-6000	V&H	Front, Rear, Left, Right	3	Note ☒ A ☐ B ☐ C	A

Note: A) There was no change compared with initial operation during the test.

B) During the test, degradation of performance is allowed. However, no change of operating state or stored data is allowed to persist after the test. If the minimum performance level (or the permissible performance loss) is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the EUT if used as intended.

C) During and after testing, a temporary loss of function is allowed, provided the function is self-recoverable, or can be restored by the operation of the controls or cycling of the power to the EUT by the user in accordance with the manufacturer's instructions.

8.5. ELECTRICAL FAST TRANSIENT (EFT)

8.5.1. TEST SPECIFICATION

Basic Standard:	IEC 61000-4-4
Test Voltage:	Power Line: ± 2 kV
Polarity:	Positive & Negative
Impulse Frequency:	5 kHz
Impulse Wave-shape:	5/50 ns
Burst Duration:	15 ms
Burst Period:	300 ms
Test Duration:	2 mins
Performance Criterion:	B

8.5.2. TEST PROCEDURE

EUT is placed on a 0.8 m tall wooden table.

EUT operate at normal mode, the transient/burst was 5/50 ns in accordance with IEC 61000-4-4, both positive and negative polarity burst waveform were applied.

The duration time of each test line was 2 minutes.

8.5.3. TEST SETUP

The EUT installed in a representative system as described in section 7 of IEC 61000-4-4.

For the actual test configuration, please refer to the related item – photographs of the test configuration.

8.5.4. TEST RESULT

Product	Switching DC Power Supply	Environmental Conditions	25.5°C, 54 % RH, 101.5 kPa
Model	305MS	Tested By	Bruce
Test mode	Full load	Test Result	Pass

Test Point	Polarity	Test Level (kV)	Observation	Performance Criterion
L	+/-	1	Note ☒ A ☐ B ☐ C	B
N	+/-	1	Note ☒ A ☐ B ☐ C	B
L – N	+/-	1	Note ☒ A ☐ B ☐ C	B
PE	+/-	1	Note ☒ A ☐ B ☐ C	B
L – PE	+/-	1	Note ☒ A ☐ B ☐ C	B
N – PE	+/-	1	Note ☒ A ☐ B ☐ C	B
L – N – PE	+/-	1	Note ☒ A ☐ B ☐ C	B
RJ45 UTP cable	--	--	N/A	N/A

Note: A) There was no change compared with initial operation during the test.

- B) During the test, degradation of performance is allowed. However, no change of operating state or stored data is allowed to persist after the test. If the minimum performance level (or the permissible performance loss) is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the EUT if used as intended.
- C) During and after testing, a temporary loss of function is allowed, provided the function is self-recoverable, or can be restored by the operation of the controls or cycling of the power to the EUT by the user in accordance with the manufacturer's instructions.



8.6. SURGE IMMUNITY TEST

8.6.1. TEST SPECIFICATION

Basic Standard:	IEC 61000-4-5
Wave-Shape:	Combination Wave 1.2/50 μ s Open Circuit Voltage 8/20 μ s Short Circuit Current
Test Voltage:	Power Port ~ Line to line: ± 1 kV
Surge Input/Output:	Power Line: L-N
Generator Source Impedance:	2 Ω between networks 12 Ω between network and ground
Polarity:	Positive/Negative
Phase Angle:	0° /90° /180° /270°
Pulse Repetition Rate:	1 time / min
Number of Tests:	5 positive polarity pulses, and 5 negative polarity pulses
Performance Criterion:	B


8.6.2. TEST PROCEDURE

EUT is placed on a 0.8 m tall wooden table.

EUT operate at normal mode, two types of combination wave generator (1.2/50 μ s open-circuit voltage and 8/20 μ s short-circuit current) are applied to the EUT power supply terminals via the capacitive coupling network.

The power cord between the EUT and the coupling/decoupling network shall not exceed 2 m in length.

8.6.3. TEST SETUP



For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

8.6.4. TEST RESULT

Product	Switching DC Power Supply	Environmental Conditions	25.5°C, 54 % RH, 101.5 kPa
Model	305MS	Tested By	Bruce
Test mode	Full load	Test Result	Pass

Test Point	Polarity	Test Level (kV)	Observation	Performance Criterion
L - N	+/-	1	Note ☒ A ☐ B ☐ C	B
L - PE	+/-	2	Note ☒ A ☐ B ☐ C	B
N - PE	+/-	2	Note ☒ A ☐ B ☐ C	B

Note: A) There was no change compared with initial operation during the test.

B) During the test, degradation of performance is allowed. However, no change of operating state or stored data is allowed to persist after the test. If the minimum performance level (or the permissible performance loss) is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the EUT if used as intended.

C) During and after testing, a temporary loss of function is allowed, provided the function is self-recoverable, or can be restored by the operation of the controls or cycling of the power to the EUT by the user in accordance with the manufacturer's instructions.

8.7. CONDUCTED RADIO FREQUENCY DISTURBANCES (CS)

8.7.1. TEST SPECIFICATION

Basic Standard:	IEC 61000-4-6
Frequency Range:	0.15 MHz ~80 MHz
Field Strength:	3 V
Modulation:	1 kHz Sine Wave, 80 %, AM Modulation
Frequency Step:	1 % of preceding frequency value
Coupled cable:	Power Mains, Shielded
Coupling device:	CDN-M3/2 (3 wires/2 wires)
Performance Criterion:	A


8.7.2. TEST PROCEDURE

The EUT shall be tested within its intended operating and climatic conditions.

The test shall be performed with the test generator connected to each of the coupling and decoupling devices in turn, while the other non-excited RF input ports of the coupling devices are terminated by a 50 Ω load resistor.

The frequency range was swept from 150 kHz to 80 MHz, using the signal level established during the setting process and with a disturbance signal of 80 % amplitude. The signal was modulated with a 1 kHz sine wave, pausing to adjust the RF signal level or the switch coupling devices as necessary. The sweep rate was 1.5×10^{-3} decades/s. Where the frequency range is swept incrementally, the step size was 1 % of preceding frequency value the dwell time of the amplitude modulated carrier at each frequency was 0.5 s.

8.7.3. TEST SETUP



For the actual test configuration, please refer to the related item – Photographs of the Test Configuration

Note: 1) The EUT is setup 0.1 m above Ground Reference Plane

2) All relevant cables shall be provided with the appropriate coupling and decoupling devices at a distance between 0.1 meters and 0.3 meters from the projected geometry of the EUT on the ground reference plane.

8.7.4. TEST RESULT

Product	Switching DC Power Supply	Environmental Conditions	25.5°C, 54 % RH, 101.5 kPa
Model	305MS	Tested By	Bruce
Test mode	Full load	Test Result	Pass

Frequency (MHz)	Field Strength (Vrms)	Injected Position	Injection Method	Observation	Performance Criterion
0.15 ~ 10	3V	AC Mains	CDN	Note ☒ A ☐ B ☐ C	A
10 ~ 30	3V-1V	AC Mains	CDN	Note ☒ A ☐ B ☐ C	A
30 ~ 80	1V	AC Mains	CDN	Note ☒ A ☐ B ☐ C	A

Note: A) There was no change compared with initial operation during the test.

B) During the test, degradation of performance is allowed. However, no change of operating state or stored data is allowed to persist after the test. If the minimum performance level (or the permissible performance loss) is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the EUT if used as intended.

C) During and after testing, a temporary loss of function is allowed, provided the function is self-recoverable, or can be restored by the operation of the controls or cycling of the power to the EUT by the user in accordance with the manufacturer's instructions.

8.8. POWER FREQUENCY MAGNETIC FIELD

8.8.1. TEST SPECIFICATION

Basic Standard:	IEC 61000-4-8
Frequency Range:	50 Hz
Field Strength:	30 A/m
Observation Time:	5 minutes
Inductance Coil:	Rectangular type, 1 m x 1 m
Performance Criterion:	A

8.8.2. TEST PROCEDURE


The equipment is configured and connected to satisfy its functional requirements. It shall be placed on the GRP with the interposition of a 0.1 m-thick insulating support.

The equipment cabinets shall be connected to the safety earth directly on the GRP via the earth terminal of the EUT.

The power supply, input and output circuits shall be connected to the sources of power supply, control and signal.

The cables supplied or recommended by the equipment manufacturer shall be used. 1 meter of all cables used shall be exposed to the magnetic field.

8.8.3. TEST SETUP



For the actual test configuration, please refer to the related item – Photographs of the Test Configuration
Note:

TABLETOP EQUIPMENT

The equipment shall be subjected to the test magnetic field by using the induction coil of standard dimension (1 m x 1 m). The induction coil shall then be rotated by 90 degrees in order to expose the EUT to the test field with different orientations.

FLOOR-STANDING EQUIPMENT

The equipment shall be subjected to the test magnetic field by using induction coils of suitable dimensions. The test shall be repeated by moving and shifting the induction coils, in order to test the whole volume of the EUT for each orthogonal direction. The test shall be repeated with the coil shifted to different positions along the side of the EUT, in steps corresponding to 50 % of the shortest side of the coil. The induction coil shall then be rotated by 90 degrees in order to expose the EUT to the test field with different orientations.

8.8.4. TEST RESULT

N/A

8.9. VOLTAGE DIP & VOLTAGE INTERRUPTIONS

8.9.1. TEST SPECIFICATION

Basic Standard:	IEC 61000-4-11
Test Duration Time:	3 test events in sequence
Interval Between Event:	10 seconds
Phase Angle:	0°
Test Cycle:	3 times
Performance Criterion:	0% UT/1 P, Criterion: B 40% UT/10 P (For 50Hz), Criterion: C 40% UT/12 P (For 60Hz), Criterion: C 70% UT/25 P (For 50Hz), Criterion: C 70% UT/30 P (For 60Hz), Criterion: C 0% UT/250 P (For 50Hz), Criterion: C 0% UT/300 P (For 60Hz), Criterion: C

8.9.2. TEST PROCEDURE


The EUT and support units were located on a wooden table, 0.8 m away from ground floor.

Setting the parameter of tests and then perform the test software of test simulator.

Changes to the voltage level shall occur at 0 degree crossing point in the a.c. voltage waveform.

Record the test result in test record form.

8.9.3. TEST SETUP



For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

**8.9.4. TEST RESULT**

Product	Switching DC Power Supply	Environmental Conditions	25.5°C, 54 % RH, 101.5 kPa
Model	305MS	Tested By	Bruce
Test mode	Full load	Test Result	Pass

Test Power: AC 230V, 50 Hz			
Voltage (% Reduction)	Duration (Period)	Observation	Performance Criterion
0	0.5	Note ☒ A ☐ B ☐ C	B
70	25	Note ☒ A ☐ B ☐ C	C
0	250	Note ☒ A ☐ B ☐ C	C

Note: A) There was no change compared with initial operation during the test.


B) During the test, degradation of performance is allowed. However, no change of operating state or stored data is allowed to persist after the test. If the minimum performance level (or the permissible performance loss) is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the EUT if used as intended.

C) During and after testing, a temporary loss of function is allowed, provided the function is self-recoverable, or can be restored by the operation of the controls or cycling of the power to the EUT by the user in accordance with the manufacturer's instructions.


9. PHOTOGRAPHS OF THE TEST CONFIGURATION CONDUCTED EMISSION TEST



RADIATED EMISSION TEST



RS TEST




ESD TEST




DIPS TEST



EFT TEST




SURGE TEST






CS TEST



10. PHOTOGRAPHS OF EUT







— End of report —